


PSV DATA

MFG: WELLMARK
 MODEL: W9503-RN
 SERIAL: 67893-4
 SET PRES: 345 kPa
 CAPACITY: 2445 scfm
 SERVICED BY: UNIFIED
 SERVICE DATE: 05/2015
 SIZE: 3in x 3in TF
 CODE STAMP: UV/NB
 BLOCK VALVE: NO
 CRN: N/S
 LOCATION: TOP SHELL
 TAG: 2415F



BC 42P686

Equip. No. _____ Prov. Reg. No. **A 68932** C.R.N. **A-6968.21** Serial No. **L-1059** Yr. Inst. _____
 Code/Div. **ASME VIII, Div 1** Size: **10ft x 25ft** Manufacturer: **NATIONAL TANK CO.** Yr. Blt. **1967**
 C. Stamp: **M** Service: **SOUR** PWHT: **NIL** Radiography: **NIL** Insulated: **ASBESTOS**

Design & Materials Data

HEAD:
 Top Mat'l. **SA 283 C** Top Nom. **11.1mm** Top C.A. **N/S**
 Btm. Mat'l. _____ Btm. Nom. _____ Btm. C.A. _____
CHANNEL:
 Material: _____ Nominal: _____ C.A. _____
BOOT
 Head Mat'l. _____ Head Nom. _____ Head C.A. _____
 Shell Mat'l. _____ Shell Nom. _____ Shell C.A. _____
SHELL
 Material: **SA 285 C** Nominal: **9.5mm** C.A. **N/S**
 MAWP Shell Side: **345 kPa** @ Temp. **149°C**
 MAWP Tube Side: _____ @ Temp. _____

| | | |
|----------|---|---------|
| CLIENT | CANADIAN NATURAL RESOURCES LTD | |
| FACILITY | NANCY BATTERY PEE JAY UNIT#3 LSD d-65-H/94-A-15 | |
| ITEM | FREE WATER KNOCK OUT DRUM | |
| BY: LO | DATE: 06/2008 | DWG.# 7 |

UTS DATA

CLIENT: CANADIAN NATURAL RESOURCES
EQUIPMENT: FREE WATER KNOCK OUT DRUM
CRN#: A-6968.21
PROV REG: A 68932
TESTED ON STREAM

FACILITY: NANCY BATTERY PEE JAY UNIT #3
SERVICE: SOUR
LOCATION: d-65-H/94-A-15
RTD JOB #: 4016101
REFER TO DRAWING: 7

| Test Point | THICKNESS DATA | | | | | | | | Flag | T-Min | C.A. | Nom. | Short Term | Long Term | Ave. mm/py | Retirement Date | | | |
|-------------|--|---|------|---|------|---|------|---|-------|-------|------|-------|------------|-----------|------------|-----------------|--|-----|------|
| 710 | Description: LOWER HEAD | | | | | | | | | | | | | | | | | | |
| | 2008 | 6 | 2011 | 2 | 2015 | 1 | 2020 | 2 | | | | | | | | | | | |
| Min. Thick. | 14.8 | | 14 | | 14 | | 14 | | 11.10 | 7.9 | | 11.10 | 0 | | .07 | | | | |
| Average: | 15.3 | | 14.9 | | 14.9 | | 14.9 | | | | | | 0 | | .03 | 2112 | | | |
| Analysis: | 02/2020 - MIN SCAN @ START OF BAND. | | | | | | | | | | | | | | | | | | |
| 715 | Description: LOWER SHELL | | | | | | | | | | | | | | | | | | |
| | 2015 | 1 | 2020 | 2 | | | | | | | | | | | | | | | |
| Min. Thick. | 9.5 | | 9.5 | | | | 9.50 | | | | 9.50 | 0 | | 0 | | | | | |
| Average: | 10 | | 10 | | | | | | | | | | | | | 0 | | 0 | |
| Analysis: | | | | | | | | | | | | | | | | | | | |
| 720 | Description: BOOT-BOTTOM HEAD | | | | | | | | | | | | | | | | | | |
| | 2008 | 6 | 2011 | 2 | 2015 | 1 | 2020 | 2 | | | | | | | | | | | |
| Min. Thick. | 9.8 | | 9.8 | | 9.8 | | 9.8 | | 0.00 | | | 0 | | 0 | | | | | |
| Average: | 11 | | 11 | | 11 | | 11 | | | | | | | | | 0 | | 0 | |
| Analysis: | 2008/06 MIN SCAN AT KNUCKLE | | | | | | | | | | | | | | | | | | |
| 725 | Description: LOWER SHELL | | | | | | | | | | | | | | | | | | |
| | 2008 | 6 | 2011 | 2 | 2015 | 1 | 2020 | 2 | | | | | | | | | | | |
| Min. Thick. | 9.6 | | 9.6 | | 9.6 | | 9.6 | | 9.50 | | | 9.50 | 0 | | 0 | | | | |
| Average: | 9.8 | | 9.8 | | 9.8 | | 9.8 | | | | | | | | | 0 | | 0 | |
| Analysis: | 2008/06 LAMINATIONS NOTED | | | | | | | | | | | | | | | | | | |
| 730 | Description: BOOT-BOTTOM HEAD | | | | | | | | | | | | | | | | | | |
| | 2008 | 6 | 2011 | 2 | 2015 | 1 | 2020 | 2 | | | | | | | | | | | |
| Min. Thick. | 9.4 | | 6.8 | | 6.8 | | 6.8 | | 0.00 | | | 0 | | .22 | | | | | |
| Average: | 11 | | 9.3 | | 9.3 | | 9.3 | | | | | | | | | 0 | | .15 | |
| Analysis: | NOTE: 2011/02 ISOLATED PIT @ SHELL TO WELD: 5.6 (MIN) & 5.9 (AVG). | | | | | | | | | | | | | | | | | | |
| 735 | Description: BOTTOM SHELL | | | | | | | | | | | | | | | | | | |
| | 2008 | 6 | 2011 | 2 | 2015 | 1 | 2020 | 2 | | | | | | | | | | | |
| Min. Thick. | 8.1 | | 8.1 | | 8.1 | | 8.1 | | 9.50 | 7.9 | | 9.50 | 0 | | 0 | | | | |
| Average: | 9 | | 9 | | 9 | | 9 | | | | | | | | | 0 | | 0 | 2028 |
| Analysis: | | | | | | | | | | | | | | | | | | | |

UTS DATA

CLIENT: CANADIAN NATURAL RESOURCES
EQUIPMENT: FREE WATER KNOCK OUT DRUM
CRN#: A-6968.21
PROV REG: A 68932
TESTED ON STREAM

FACILITY: NANCY BATTERY PEE JAY UNIT #3
SERVICE: SOUR
LOCATION: d-65-H/94-A-15
RTD JOB #: 4016101
REFER TO DRAWING: 7

| Test Point | THICKNESS DATA | | Flag | T-Min | C.A. | Nom. | Short Term | Long Term | Ave. mm/py | Retirement Date |
|------------|--|-----|------|-------|------|------|------------|-----------|------------|-----------------|
| 736 | Description: BOOT - SHELL 2020 2 | | | | | | | | | |
| | Min. Thick. | 7.5 | 0.00 | | | | | | | |
| | Average: | 7.7 | | | | | 0 | 0 | | |
| | Analysis: | | | | | | | | | |
| 737 | Description: BOOT - HEAD 2020 2 | | | | | | | | | |
| | Min. Thick. | 7 | 0.00 | | | | | | | |
| | Average: | 7.5 | | | | | 0 | 0 | | |
| | Analysis: | | | | | | | | | |
| 738 | Description: BOOT - HEAD 2020 2 | | | | | | | | | |
| | Min. Thick. | 7 | 0.00 | | | | | | | |
| | Average: | 7.5 | | | | | 0 | 0 | | |
| | Analysis: | | | | | | | | | |
| 739 | Description: 4" CIRC NOZZLE 2020 2 | | | | | | | | | |
| | Min. Thick. | 7.9 | 8.60 | 2.5 | | 8.60 | | | | |
| | Average: | 8.1 | | | | | 0 | 0 | | 2429 |
| | Analysis: 02/2020 - THICKNESS CALCULATIONS CARRIED OUT TO 0.1mm. API 510 REFERENCES 2.5mm AS MINIMUM THICKNESS REQUIRED FOR PRESSURE VESSELS AND PIPING. | | | | | | | | | |

UTS DATA

CLIENT: CANADIAN NATURAL RESOURCES
EQUIPMENT: FREE WATER KNOCK OUT DRUM PIPING
CRN#:
PROV REG:
TESTED ON STREAM

FACILITY: NANCY BATTERY PEE JAY UNIT #3
SERVICE: SOUR
LOCATION: d-65-H/94-A-15
RTD JOB #: 4016101
REFER TO DRAWING: 7

| Test Point | THICKNESS DATA | | | | | | | | Flag | T-Min | C.A. | Nom. | Short Term | Long Term | Ave. mm/py | Retirement Date |
|--|----------------|---|------|---|------|---|------|---|------|-------|------|------|------------|-----------|------------|-----------------|
| 705 | | | | | | | | | | | | | | | | |
| Description: 4" 90° ELBOW | | | | | | | | | | | | | | | | |
| | 2008 | 6 | 2011 | 2 | 2015 | 1 | 2020 | 2 | | | | | | | | |
| Min. Thick. | 5.9 | | 5.9 | | 5.9 | | 5.9 | | 5.25 | | .8 | 6.00 | 0 | 0 | | |
| Average: | 6.3 | | 6.3 | | 6.3 | | 6.3 | | | | | | 0 | 0 | | |
| Analysis: | | | | | | | | | | | | | | | | |
| 740 | | | | | | | | | | | | | | | | |
| Description: 4" 90° ELBOW | | | | | | | | | | | | | | | | |
| | 2008 | 6 | 2011 | 2 | 2015 | 1 | 2020 | 2 | | | | | | | | |
| Min. Thick. | 8.6 | | 8.6 | | 8.6 | | 8.6 | | 7.53 | | 1.1 | 8.60 | 0 | 0 | | |
| Average: | 8.9 | | 8.9 | | 8.9 | | 8.9 | | | | | | 0 | 0 | | |
| Analysis: | | | | | | | | | | | | | | | | |
| 742 | | | | | | | | | | | | | | | | |
| Description: 4" 90° ELBOW | | | | | | | | | | | | | | | | |
| | 2015 | 1 | 2020 | 2 | | | | | | | | | | | | |
| Min. Thick. | 5.7 | | 5.7 | | | | | | 5.25 | | .8 | 6.00 | 0 | 0 | | |
| Average: | 5.9 | | 5.9 | | | | | | | | | | 0 | 0 | | |
| Analysis: | | | | | | | | | | | | | | | | |
| 745 | | | | | | | | | | | | | | | | |
| Description: 2" 90° ELBOW | | | | | | | | | | | | | | | | |
| | 2008 | 6 | 2011 | 2 | 2015 | 1 | 2020 | 2 | | | | | | | | |
| Min. Thick. | 5.6 | | 5.6 | | 5.6 | | 5.3 | | 4.81 | | .7 | 5.50 | .06 | .03 | | |
| Average: | 5.8 | | 5.8 | | 5.8 | | 5.6 | | | | | | .04 | .02 | | |
| Analysis: | | | | | | | | | | | | | | | | |
| 747 | | | | | | | | | | | | | | | | |
| Description: 3" 90° ELBOW | | | | | | | | | | | | | | | | |
| | 2015 | 1 | 2020 | 2 | | | | | | | | | | | | |
| Min. Thick. | 5.3 | | 5.3 | | | | | | 4.81 | | .7 | 5.50 | 0 | 0 | | |
| Average: | 5.6 | | 5.6 | | | | | | | | | | 0 | 0 | | |
| Analysis: | | | | | | | | | | | | | | | | |
| 758 | | | | | | | | | | | | | | | | |
| Description: 3" CIRC BAND | | | | | | | | | | | | | | | | |
| | 2015 | 1 | 2020 | 2 | | | | | | | | | | | | |
| Min. Thick. | 5 | | 5 | | | | | | 6.65 | 2.5 | 1 | 7.60 | 0 | 0 | | |
| Average: | 6.1 | | 6.1 | | | | | | | | | | 0 | 0 | | |
| Analysis: 02/2020 - THICKNESS CALCULATIONS CARRIED OUT TO 0.1mm. API 510 REFERENCES 2.5mm AS MINIMUM THICKNESS REQUIRED FOR PRESSURE VESSELS AND PIPING. RETIREMENT DATE 2071. | | | | | | | | | | | | | | | | |

UTS DATA

CLIENT: CANADIAN NATURAL RESOURCES
EQUIPMENT: FREE WATER KNOCK OUT DRUM PIPING
CRN#:
PROV REG:
TESTED ON STREAM

FACILITY: NANCY BATTERY PEE JAY UNIT #3
SERVICE: SOUR
LOCATION: d-65-H/94-A-15
RTD JOB #: 4016101
REFER TO DRAWING: 7

| Test Point | THICKNESS DATA | | | | | | | | Flag | T-Min | C.A. | Nom. | Short Term | Long Term | Ave. mm/py | Retirement Date | | | | | |
|--------------|--|---|------|-----|------|------|------|------|------|-------|------|------|------------|-----------|------------|-----------------|---|--|--|---|---|
| 759 | | | | | | | | | | | | | | | | | | | | | |
| Description: | 3" CIRC BAND | | | | | | | | | | | | | | | | | | | | |
| | 2015 | 1 | 2020 | 2 | | | | | | | | | | | | | | | | | |
| Min. Thick. | 3.4 | | 3.4 | | 6.65 | 2.5 | 1 | 7.60 | 0 | 0 | | | | | | | | | | | |
| Average: | 5.6 | | 5.6 | | | | | | | | | | | | | 0 | 0 | | | | |
| Analysis: | 02/2020 - CORROSION AT 6 O'CLOCK POSITION. THICKNESS CALCULATIONS CARRIED OUT TO 0.1mm. API 510 REFERENCES 2.5mm AS MINIMUM THICKNESS REQUIRED FOR PRESSURE VESSELS AND PIPING. RETIREMENT DATE | | | | | | | | | | | | | | | | | | | | |
| 760 | | | | | | | | | | | | | | | | | | | | | |
| Description: | 3" 90° ELBOW | | | | | | | | | | | | | | | | | | | | |
| | 2020 | 2 | | | | | | | | | | | | | | | | | | | |
| Min. Thick. | 6.8 | | 6.65 | | 1 | 7.60 | 0 | 0 | | | | | | | | | | | | | |
| Average: | 7.1 | | | | | | | | | | | | | | | 0 | 0 | | | | |
| Analysis: | | | | | | | | | | | | | | | | | | | | | |
| 780 | | | | | | | | | | | | | | | | | | | | | |
| Description: | 3" 90° ELBOW | | | | | | | | | | | | | | | | | | | | |
| | 2008 | 6 | 2011 | 2 | 2015 | 1 | 2020 | 2 | | | | | | | | | | | | | |
| Min. Thick. | 6.9 | | 6.9 | | 6.9 | | 6.9 | | 6.65 | 1 | 7.60 | 0 | 0 | | | | | | | | |
| Average: | 7.2 | | 7.2 | | 7.2 | | 7.2 | | | | | | | | | | | | | 0 | 0 |
| Analysis: | | | | | | | | | | | | | | | | | | | | | |
| 785 | | | | | | | | | | | | | | | | | | | | | |
| Description: | 4" CIRC BAND | | | | | | | | | | | | | | | | | | | | |
| | 2008 | 6 | 2011 | 2 | 2015 | 1 | 2020 | 2 | | | | | | | | | | | | | |
| Min. Thick. | 8.2 | | 8.2 | | 8.2 | | 8.2 | | 7.53 | 1.1 | 8.60 | 0 | 0 | | | | | | | | |
| Average: | 8.7 | | 8.7 | | 8.7 | | 8.7 | | | | | | | | | | | | | 0 | 0 |
| Analysis: | 2008/06 MIN SCAN AT 6:00 POSITION | | | | | | | | | | | | | | | | | | | | |
| 790 | | | | | | | | | | | | | | | | | | | | | |
| Description: | 4" CIRC BAND | | | | | | | | | | | | | | | | | | | | |
| | 2008 | 6 | 2011 | 2 | 2015 | 1 | 2020 | 2 | | | | | | | | | | | | | |
| Min. Thick. | 8.1 | | 8.1 | | 8.1 | | 8.1 | | 7.53 | 1.1 | 8.60 | 0 | 0 | | | | | | | | |
| Average: | 8.4 | | 8.4 | | 8.4 | | 8.4 | | | | | | | | | | | | | 0 | 0 |
| Analysis: | 2008/06 MIN SCAN AT 6:00 POSITION | | | | | | | | | | | | | | | | | | | | |
| 795 | | | | | | | | | | | | | | | | | | | | | |
| Description: | 4" 90° ELBOW | | | | | | | | | | | | | | | | | | | | |
| | 2020 | 2 | | | | | | | | | | | | | | | | | | | |
| Min. Thick. | 7.1 | | 7.53 | 2.5 | 1.1 | 8.60 | .08 | .05 | | | | | | | | | | | | | |
| Average: | 8 | | | | | | | | | | | | | | | 0 | 0 | | | | |
| Analysis: | 02/2020 - NEW PIPING. MIN SCAN @ WELDS. THICKNESS CALCULATIONS CARRIED OUT TO 0.1mm. API 510 REFERENCES 2.5mm AS MINIMUM THICKNESS REQUIRED FOR PRESSURE VESSELS AND PIPING. RETIREMENT DATE 2183. | | | | | | | | | | | | | | | | | | | | |

UTS DATA

CLIENT: CANADIAN NATURAL RESOURCES
EQUIPMENT: FREE WATER KNOCK OUT DRUM PIPING
CRN#:
PROV REG:
TESTED ON STREAM

FACILITY: NANCY BATTERY PEE JAY UNIT #3
SERVICE: SOUR
LOCATION: d-65-H/94-A-15
RTD JOB #: 4016101
REFER TO DRAWING: 7

| Test Point | THICKNESS DATA | | | | Flag | T-Min | C.A. | Nom. | Short Term | Long Term | Ave. mm/py | Retirement Date |
|--------------|--|------|-----|----|------|-------|------|------|------------|-----------|------------|-----------------|
| 796 | | | | | | | | | | | | |
| Description: | 2" CIRC BAND | | | | | | | | | | | |
| | 2020 2 | | | | | | | | | | | |
| Min. Thick. | 4.7 | 4.81 | 2.5 | .7 | 5.50 | | | | | | | |
| Average: | 5 | | | | | | | 0 | 0 | | | |
| Analysis: | 02/2020 - THICKNESS CALCULATIONS CARRIED OUT TO 0.1mm. API 510 REFERENCES 2.5mm AS MINIMUM THICKNESS REQUIRED FOR PRESSURE VESSELS AND PIPING. RETIREMENT DATE 2166. | | | | | | | | | | | |

| | | | | | | | | | | | | |
|--------------|---|------|-----|----|------|--|--|---|---|--|--|--|
| 797 | | | | | | | | | | | | |
| Description: | 2" CIRC BAND | | | | | | | | | | | |
| | 2020 2 | | | | | | | | | | | |
| Min. Thick. | 4 | 4.81 | 2.5 | .7 | 5.50 | | | | | | | |
| Average: | 4.5 | | | | | | | 0 | 0 | | | |
| Analysis: | 02/2020 - CORROSION NOTED. THICKNESS CALCULATIONS CARRIED OUT TO 0.1mm. API 510 REFERENCES 2.5mm AS MINIMUM THICKNESS REQUIRED FOR PRESSURE VESSELS AND PIPING. RETIREMENT DATE 2073. | | | | | | | | | | | |