

# **PSV Inventory**

[www.mtnwest.ca] [Company Index Page] [Vessels] [Pipelines] [SMART] [Incidents] [Work Orders] [Management of Change]

| Status:                            | In Service            | Back Pressure:            | 0 PSI 0 KPa                     |  |
|------------------------------------|-----------------------|---------------------------|---------------------------------|--|
| LSD:                               | <u>03-03-072-26W5</u> | Inlet Size:               | 2.5 IN 63.5 MM                  |  |
| District/Unit:                     | PPLT                  | Outlet Size:              | 4 IN 101.6 MM                   |  |
| Location:                          | PUSKWA PLANT          | Capacity:                 | 35956 SCFM 1018.16<br>m3/min    |  |
| Skid/Equipment<br>Number:          | V-111                 | Inlet Block Valves:       | No Locked Open?: NA             |  |
| CRN:                               | OG8442.5C             | Outlet Block Valves:      | No Locked Open?: NA             |  |
| Make::                             | FARRIS                | Process:                  | Sweet Gas                       |  |
| Model:                             | 26JA13-120            | <b>ANSI Rating Inlet:</b> | 600                             |  |
| Code Stamp:                        | UV                    | ANSI Rating Outlet:       | 150                             |  |
| Serial Number:                     | 528088-2-A10          | Location on Vessel:       | TOP OF V-111 INLET<br>SEPARATOR |  |
| Set Pressure:                      | 1440 PSI 9928.51 KF   | Pa                        |                                 |  |
| [Click here for extended PSV data] |                       |                           |                                 |  |

## P80451

### **List of Service Reports:**

| Last Inspection: 8/1/2008 | Inspecting Company: FARRIS | Condition: New             |  |  |
|---------------------------|----------------------------|----------------------------|--|--|
| Service Interval: 60      | Company Reference No.:     | Service: Sweet             |  |  |
| Next Inspection: 8/1/2013 | Technician Name:           | <b>Installed:</b> 8/1/2008 |  |  |
| Pre-Test: No              | Pre-Test Results:          |                            |  |  |
| Comments:                 |                            |                            |  |  |

| Last Inspection: 5/13/2012 | Inspecting Company: KINGS        | Condition: Good     |
|----------------------------|----------------------------------|---------------------|
| Service Interval: 60       | Company Reference No.: JOB#43101 | Service: Sweet      |
| Next Inspection: 5/13/2017 | Technician Name:                 | Installed: 8/1/2008 |
| Pre-Test: Yes              | Pre-Test Results: Pass           |                     |
| Comments:                  |                                  |                     |

#### **Pictures and Attachments**

### **This PSV Protects Vessels:**

Vessel Number: 578137 - INLET SEPARATOR - Side: Shell - Primary:Yes

NCRs:

**Material Transfer Orders:** 

**Satellite Images Found:** 

[Click Here For Satellite Picture]

Record Entered: 11/4/2008 Record Last Updated: 2/4/2013

[Back To Start Page] [MtnWest.Ca]