


ITEM:

3PH SEPARATOR

A0578137



STETTNER, AB (403) 742-4868
 LACOMBE, AB (403) 782-7855
 BROOKS, AB (403) 501-8029
 GRANDE PRAIRIE, AB (866) 422-9732

TECHNICIAN:

PHILIP SACREY
 SNT LEVEL I
 CGSB 48.9712
 LEVEL I # 17106

DATE: 5/01/12

DWG: 72

CLIENT: BARRICK ENERGY INC.

LSID: 03-03-072-26-W5M

INSPECTOR: MWS

LOCATION: NORTHERN AB

DISTRICT UNIT: PUSKWA PLANT

BLDG/SKID: PKG62369

PROCESS: SWEET

CODE: ASME SEC VIII DIV 1

SPECIFICATION: AS PER ASME SE 797

TECHNIQUE: UT 1-1, REV. 1

METHOD: UT CONTINUOUS / A SCAN

SURFACE COND: PAINTED

SURFACE TEMP: AMBIENT

VESSEL INFORMATION

VESSEL #: A0578137

CRN #: U1422.213

SERIAL #: HS-13824

MANUFACTURER: LARSEN & D'AMICO

DATE BUILT: 2007

CLIENT ID / TAG: V-111

M.A.W.P.: 1440 PSI

M.A.W.T.: 129° F

JOINT EFFICIENCY/RT: RT 1

STRESS RELIEVED: YES

INSULATED: NO

MANWAY: YES

VESSEL SPECIFICATIONS

	OD	NOMINAL	MATERIAL	CA
VESSEL HEAD	48"	1.880"	SA-516-70	.125"
VESSEL SHELL	48"	2.000"	SA-516-70	.125"
BOOT HEAD	-	-	-	-
BOOT SHELL	-	-	-	-

COMMENTS:

PROJECT: C50102